



中国节能产品认证证书

证书编号: CQC20701269082

申请人名称及地址: 深圳力锐斯电子有限公司
深圳市宝安区沙井街道万丰大洋田工业区第9、10、11、12
栋的10栋三楼东面

品 牌: 力锐斯

制造商名称及地址: 深圳力锐斯电子有限公司
深圳市宝安区沙井街道万丰大洋田工业区第9、10、11、12
栋的10栋三楼东面

生产企业名称及地址: 深圳力锐斯电子有限公司
深圳市宝安区沙井街道万丰大洋田工业区第9、10、11、12
栋的10栋三楼东面

产 品 名 称: 不间断电源

系 列/规 格/型 号: 如附件

认 证 模 式: 产品检验+初始工厂检查+获证后监督

产品标准/技术要求: CQC3108-2011

上述产品符合 CQC31-461234-2009 认证规则的要求, 特此发证。

证 书 有 效 期: 2020年10月16日至2025年10月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P



主任:

陆梅



中国质量认证中心



CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO.: CQC20701269082

NAME AND ADDRESS
OF THE APPLICANT:

Shengzhen Lpsrits Electronic Co Ltd
3/F East Building 10 Dayangtian Industrial Park Wanfeng shajing street
Bao an District shenzhen Guangdong china

BRAND NAME:

力锐斯

NAME AND ADDRESS
OF THE MANUFACTURER:

Shengzhen Lpsrits Electronic Co Ltd
3/F East Building 10 Dayangtian Industrial Park Wanfeng shajing street
Bao an District shenzhen Guangdong china

NAME AND ADDRESS
OF THE FACTORY:

Shengzhen Lpsrits Electronic Co Ltd
3/F East Building 10 Dayangtian Industrial Park Wanfeng shajing street
Bao an District shenzhen Guangdong china

PRODUCT NAME:

UPS

PRODUCT MODEL AND
SPECIFICATION:

如附件

TYPE OF CERTIFICATION
SCHEMES:

Product Testing + Initial Factory Inspection + Follow up Factory
Inspection

THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS:

CQC3108-2011

This is to certify that the above mentioned product(s) complies with the requirements of
CQC31-461234-2009 .

Valid from: Oct.16,2020

Valid until: Oct.16,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by
issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国节能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC20701269082

纸号: 177696

型号	输入	输出	容量	外形尺寸(mm)
HY 10KVA	3Φ+N+PE 380Vac, 17A, 50Hz	3Φ+N+PE 380Vac, 15A, 50Hz	10kVA/10kW 功率因数 1.0	525*250*826
HY 15KVA	3Φ+N+PE 380Vac, 25A, 50Hz	3Φ+N+PE 380Vac, 23A, 50Hz	15kVA/15kW 功率因数 1.0	525*250*826
HY 20KVA	3Φ+N+PE 380Vac, 34A, 50Hz	3Φ+N+PE 380Vac, 30A, 50Hz	20kVA/20kW 功率因数 1.0	525*250*826
HY 30KVA	3Φ+N+PE 380Vac, 51A, 50Hz	3Φ+N+PE 380Vac, 46A, 50Hz	30kVA/30kW 功率因数 1.0	800*250*826
HY 40KVA	3Φ+N+PE 380Vac, 68A, 50Hz	3Φ+N+PE 380Vac, 46A, 50Hz	40kVA/40kW 功率因数 1.0	700*300*960
HY 50KVA	3Φ+N+PE 380Vac, 85A, 50Hz	3Φ+N+PE 380Vac, 76A, 50Hz	50kVA/50kW 功率因数 1.0	700*300*960
HY 60KVA	3Φ+N+PE 380Vac, 102A, 50Hz	3Φ+N+PE 380Vac, 91 A, 50Hz	60kVA/60kW 功率因数 1.0	700*300*960
HY 80KVA	3Φ+N+PE 380Vac, 136A, 50Hz	3Φ+N+PE 380Vac, 122A, 50Hz	80kVA/80kW 功率因数 1.0	700*300*960
HY 90KVA	3Φ+N+PE 380Vac, 153A, 50Hz	3Φ+N+PE 380Vac, 137A, 50Hz	90kVA/90kW 功率因数 1.0	850*442*1200



主任:

陆梅



中国质量认证中心